

---

## AB 2370 Assistance - Sampling Results are Available for Facility Number(s): 197407441

---

AB 2370 Assistance Program <ab2370assistance@owp.csus.edu>  
To: Recipient <robert@halseyschools.com>

Thu, Oct 20, 2022 at 4:19 PM



---

### Your Child Care Center Contact Information

Facility Owner/Operator: Robert Rice  
Facility Number(s): 197407441  
Facility Name(s): HALSEY SCHOOLS, INCORPORATED (INFANT CENTER)  
Facility Address: [5319 COMERCIO WAY, WOODLAND HILLS, CA 91364](#)  
Licensee: HALSEY SCHOOLS, INCORPORATED

---

### Sampling Results are Posted (No Action Required)

Congratulations! Your water samples have been tested and the results submitted to the State Water Board's™ Division of Drinking Water. No exceedances were found, which means that no further action is required from you right now. You will need to retest your outlets every 5 years to comply with the Written Directives outlined in [PIN 21-21-CCP](#).

For your records, the laboratory report can be downloaded from the [Provider Portal](#) by clicking on View Documents. You will also be receiving notification of testing results from the Department of Social Services (CDSS). As a reminder, The Written Directives, section 101703(b) requires the results to be posted within 24 hours of receiving notification from CDSS.

### Lead Sampling Results

Sample ID	Location	Result	Action Level Exceedance
197407441 C	Sink Faucet_ Room 2	< 1.00 UG/L	No
197407441 E	Sink Faucet_ Room 3	< 1.00 UG/L	No
197407441 F	Sink Faucet_ Kitchen	< 1.00 UG/L	No
197407441 F30	Sink Faucet_ Kitchen - FLUSHED	< 1.00 UG/L	No

We thank you for your participation in this program!

If you have any questions, send us an email at [ab2370assistance@owp.csus.edu](mailto:ab2370assistance@owp.csus.edu) or call our

help desk at (916) 278-6142.

For website function and other questions, email OWP at [ab2370assistance@owp.csus.edu](mailto:ab2370assistance@owp.csus.edu) (quicker response) or call and leave a voicemail at (916) 278-6142. Please include your facility number.

---

Data collected and generated by this project may be used by the State of California and its contractor within the limits of the law and the terms of the agreement between the State and the project contractor.

---



3020 State University Drive, Modoc Hall Suite 1001, Sacramento, CA 95819



California  
Rural Water Association



California Child Care Resource & Referral  
NETWORK



---

*This is an automated email from the Assistance Team for the drinking water testing assistance program for child care centers (<https://ab2370assistance.owp.csus.edu/>) administered by the Office of Water Programs at California State University, Sacramento (<https://owp.csus.edu/>). If this message reached you in error, please forward it to [ab2370assistance@owp.csus.edu](mailto:ab2370assistance@owp.csus.edu) so we can remove your email address from our contact list.*

## Result Summary for 469034

Lisa Yang  
 California Rural Water Association  
 1234 North Market Blvd.  
 Sacramento, CA 95834

Lab Job #: 469034  
 Location: Halsey Schools, Incorporated (Infant)\_Lead  
 Sampling  
 Date Received: 09/13/22

**Sample ID: 197407441 C**      **Lab ID: 469034-001**      **Collected: 09/12/22 06:20**  
**Matrix: Drinking Water**

C-Sink Faucet\_Room 2

469034-001 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8						
Prep Method: METHOD						
Lead	ND		ug/L	1.0	1	THP

**Sample ID: 197407441 E**      **Lab ID: 469034-002**      **Collected: 09/12/22 06:30**  
**Matrix: Drinking Water**

E-Sink Faucet\_Room 3

469034-002 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8						
Prep Method: METHOD						
Lead	ND		ug/L	1.0	1	THP

**Sample ID: 197407441 F**      **Lab ID: 469034-003**      **Collected: 09/12/22 06:35**  
**Matrix: Drinking Water**

F-Sink Faucet\_Kitchen

469034-003 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8						
Prep Method: METHOD						
Lead	ND		ug/L	1.0	1	THP

**Sample ID: 197407441 F30**      **Lab ID: 469034-004**      **Collected: 09/12/22 06:45**  
**Matrix: Drinking Water**

F-Sink Faucet\_Kitchen-FLUSHED

469034-004 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8						
Prep Method: METHOD						
Lead	ND		ug/L	1.0	1	THP

ND Not Detected

## Result Summary for 469034