
**AB 2370 Assistance - Sampling Results are Available for Facility
Number(s): 197407439**

AB 2370 Assistance Program <ab2370assistance@owp.csus.edu>
To: Recipient <Robert@halseyschools.com>

Thu, Oct 20, 2022 at 4:19 PM



Your Child Care Center Contact Information

Facility Owner/Operator: Robert Rice
Facility Number(s): 197407439
Facility Name(s): HALSEY SCHOOLS, INCORPORATED (DAY CARE CENTER)
Facility Address: [21321 COSTANSO ST, WOODLAND HILLS, CA 91364](#)
Licensee: HALSEY SCHOOLS, INCORPORATED

Sampling Results are Posted (No Action Required)

Congratulations! Your water samples have been tested and the results submitted to the State Water Board's™ Division of Drinking Water. No exceedances were found, which means that no further action is required from you right now. You will need to retest your outlets every 5 years to comply with the Written Directives outlined in [PIN 21-21-CCP](#).

For your records, the laboratory report can be downloaded from the [Provider Portal](#) by clicking on View Documents. You will also be receiving notification of testing results from the Department of Social Services (CDSS). As a reminder, The Written Directives, section 101703(b) requires the results to be posted within 24 hours of receiving notification from CDSS.

Lead Sampling Results

Sample ID	Location	Result	Action Level Exceedance
197407439 A	Sink faucet_ Room 1	3.50 UG/L	No
197407439 A30	Sink Faucet_ Room 1 - FLUSHED	1.30 UG/L	No
197407439 C	Sink Faucet_ Room 5	1.70 UG/L	No

We thank you for your participation in this program!

If you have any questions, send us an email at ab2370assistance@owp.csus.edu or call our help desk at [\(916\) 278-6142](tel:(916)278-6142).

For website function and other questions, email OWP at ab2370assistance@owp.csus.edu (quicker response) or call and leave a voicemail at (916) 278-6142. Please include your facility number.

Data collected and generated by this project may be used by the State of California and its contractor within the limits of the law and the terms of the agreement between the State and the project contractor.



3020 State University Drive, Modoc Hall Suite 1001, Sacramento, CA 95819



California
Rural Water Association



California Child Care Resource & Referral
NETW40RK



This is an automated email from the Assistance Team for the drinking water testing assistance program for child care centers (<https://ab2370assistance.owp.csus.edu/>) administered by the Office of Water Programs at California State University, Sacramento (<https://owp.csus.edu/>). If this message reached you in error, please forward it to ab2370assistance@owp.csus.edu so we can remove your email address from our contact list.

Result Summary for 469036

Lisa Yang
 California Rural Water Association
 1234 North Market Blvd.
 Sacramento, CA 95834

Lab Job #: 469036
 Location: Halsey Schools, Incorporated (Day
 Care)_Lead Sampling
 Date Received: 09/13/22

Sample ID: 197407439 A	Lab ID: 469036-001	Collected: 09/12/22 06:05
	Matrix: Drinking Water	

A- SINK FAUCET_ROOM 1

469036-001 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8						
Prep Method: METHOD						
Lead	3.5		ug/L	1.0	1	THP

Sample ID: 197407439 A30	Lab ID: 469036-002	Collected: 09/12/22 06:10
	Matrix: Drinking Water	

A- SINK FAUCET_ROOM 1- FLUSHED

469036-002 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8						
Prep Method: METHOD						
Lead	1.3		ug/L	1.0	1	THP

Sample ID: 197407439 C	Lab ID: 469036-003	Collected: 09/12/22 06:15
	Matrix: Drinking Water	

C- SINK FAUCET_ROOM 5

469036-003 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8						
Prep Method: METHOD						
Lead	1.7		ug/L	1.0	1	THP